

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE <div style="text-align: center;">J</div>		PAGE OF PAGES <div style="display: flex; justify-content: space-between;"><div>1</div><div>5</div></div>	
2. AMENDMENT/MODIFICATION NO. <div style="text-align: center;">0003</div>		3. EFFECTIVE DATE <div style="text-align: center;">23-Jan-2004</div>		4. REQUISITION/PURCHASE REQ. NO. <div style="text-align: center;">W81G67-2351-2489</div>		5. PROJECT NO.(If applicable)	
6. ISSUED BY <div style="font-size: small;">CONTRACTING DIVISION USACE - ST. PAUL 190 5TH STREET E ST. PAUL MN 55101</div>		CODE <div style="text-align: center;">W912ES</div>		7. ADMINISTERED BY (If other than item 6) <div style="text-align: center; font-weight: bold;">See Item 6</div>			
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)				X		9A. AMENDMENT OF SOLICITATION NO. <div style="text-align: center;">DACW37-03-B-0004</div>	
				X		9B. DATED (SEE ITEM 11) <div style="text-align: center;">18-Dec-2003</div>	
						10A. MOD. OF CONTRACT/ORDER NO.	
						10B. DATED (SEE ITEM 13)	
CODE		FACILITY CODE					
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS							
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended.  Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.							
12. ACCOUNTING AND APPROPRIATION DATA (If required)							
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.							
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.							
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).							
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:							
D. OTHER (Specify type of modification and authority)							
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.							
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) This amendment is to make changes to specifications and drawings.  The response date remains 4 Feb 2004.							
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.							
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)			
				TEL: _____ EMAIL: _____			
15B. CONTRACTOR/OFFEROR  _____ <div style="font-size: x-small;">(Signature of person authorized to sign)</div>		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA  BY _____ <div style="font-size: x-small;">(Signature of Contracting Officer)</div>		16C. DATE SIGNED	

## SECTION SF 30 BLOCK 14 CONTINUATION PAGE

**SUMMARY OF CHANGES****A. CHANGES TO DRAWINGS:**

1. Contract Drawing No R-P-GF-00/0037, Sheet 4 of 328:  
Add the following: "General Note # 10: Any excess excavation material shall become the property of the contractor and disposed of off-site."
2. Contract Drawing No R-P-GF-64/1289, Sheet 28 of 328:  
Flood Wall Profile, place expansion joint at flood wall change in direction, at PI R1-25. (PI is shown on levee plan drawing 64/1272) Location: STA 151+10 place expansion joint in flood wall 30 feet from levee tie in at approximate STA 150+80.
3. Contract Drawing No R-P-GF-64/1435, Sheet 158 of 328:  
Coordinates B6; SECTION 2; TYPICAL SECTION ABUTMENT. Delete "# 4 LOOP @ 12" (UPPER HALF)" and Change "# 4 LOOP @ 6" (BOTTOM HALF)" to "# 4 LOOP @ 6" (FULL HEIGHT)".
4. Contract Drawing No R-P-GF-64/1404C, Sheet 127 of 328:  
Revise the following: "Outlet Structure see drawing should read: Detention Pond Outlet Weir, see detail U, drawing 64/1305."
5. Contract Drawing No R-P-GF-64/1404E, Sheet 129 of 328:  
Revise the following on Detail Z, table: "Changes units on Rt to be inches"
6. Remove drawing R-P-GF-64/1325 and replace with amended drawing R-P-GF-64/1325 which is attached to and part of this amendment.
7. Remove drawing R-P-GF-64/1342 and replace with amended drawing R-P-GF-64/1342 which is attached to and part of this amendment.
8. Remove drawing R-P-GF-64/1346 and replace with amended drawing R-P-GF-64/1346 which is attached to and part of this amendment.
9. Remove drawing R-P-GF-64/1349 and replace with amended drawing R-P-GF-64/1349 which is attached to and part of this amendment.
10. Remove drawing R-P-GF-64/1435 and replace with amended drawing R-P-GF-64/1435 which is attached to and part of this amendment.
11. Remove drawing R-P-GF-64/1439 and replace with amended drawing R-P-GF-64/1439 which is attached to and part of this amendment.
12. Contract Drawing No R-P-GF-64/1270, Sheet 13 of 328:  
Add the following: "Note 3. Provide a 6-ft tall security chain link fence with one access gate around the perimeter of Gated Outlet A3. The perimeter of chain link fence shall be 3 feet off the face of the top slab of the structure. Posts shall have a maximum spacing of 12 feet on center. The posts shall embed 3 feet into a 10 inch diameter, 3 feet 6 inch deep concrete cylinder with the top of the cylinder crowned 1 inch minimum or 2 inch maximum or according to manufacturer's requirements, whichever is more stringent."
13. Contract Drawing No R-P-GF-64/1385, Sheet 107 of 328:

- Add the following: “Note 8. Provide a 6-ft tall security chain link fence with one access gate around the perimeter of Gated Outlet H4. The perimeter of chain link fence shall be 3 feet off the face of the top slab of the structure. Posts shall have a maximum spacing of 12 feet on center. The posts shall embed 3 feet into a 10 inch diameter, 3 feet 6 inch deep concrete cylinder with the top of the cylinder crowned 1 inch minimum or 2 inch maximum or according to manufacturer’s requirements, whichever is more stringent.”
14. Contract Drawing No R-P-GF-64/1414, Sheet 141 of 328:  
Replace the Following: “Section 39: Change #6 @ 12” on base slab to #7 @ 12”
  15. Contract Drawing No R-P-GF-64/1414, Sheet 141 of 328:  
Drawing R-P-GF-64/1414, Section 48. Under "18" RCP" change "SEE NOTE 12" to "SEE NOTE 11"
  16. Contract Drawing No R-P-GF-64/1416, Sheet 143 of 328:  
Replace the Following: “Detail C: Change A3-2 to read A1”
  17. Contract Drawing No R-P-GF-64/1440, Sheet 163 of 328:  
Coordinates B-3, Table for "GRAND FORKS FLOOD WALL REACH 1" delete the entire line beginning with "63+27 TO 77+28".
  18. Contract Drawing No R-P-GF-64/1452, Sheet 173 of 328:  
Add the following: “Note 4. Provide a 6 ft tall security chain link fence with one access gate around the perimeter of Discharge Chamber A1. The perimeter of chain link fence shall be 3 feet off the face of the top slab of the structure. Posts shall have a maximum spacing of 12 feet on center. The posts shall embed 3 feet into a 10 inch diameter, 3 feet 6 inch deep concrete cylinder with the top of the cylinder crowned 1 inch minimum or 2 inch maximum or according to manufacturer’s requirements, whichever is more stringent.”
  19. Contract Drawing No R-P-GF-64/1478, Sheet 196 of 328:  
Remove the Following: Section 26, Gated Outlet: Remove guardrail.
  20. Contract Drawing No R-P-GF-64/1480, Sheet 197 of 328:  
Add the following: “Note 4. Provide a 6-ft tall security chain link fence with one access gate around the perimeter of Gated Outlet C4. The perimeter of chain link fence shall be 3 feet off the face of the top slab of the structure. Posts shall have a maximum spacing of 12 feet on center. The posts shall embed 3 feet into a 10 inch diameter, 3 feet 6 inch deep concrete cylinder with the top of the cylinder crowned 1 inch minimum or 2 inch maximum or according to manufacturer’s requirements, whichever is more stringent.”
  21. Contract Drawing No R-P-GF-64/1482, Sheet 199 of 328:
    - a. Remove the Following: Section 33, Gated Outlet: Remove guardrail.
    - b. Change the following: Note 5: Delete the second sentence and replace with “All supporting hardware shall be stainless steel hardware.”
  22. Contract Drawing No R-P-GF-64/1484, Sheet 200 of 328:  
Add the following: “Note 4. Provide a 6-ft tall security chain link fence with one access gate around the perimeter of Discharge Chamber C5. The perimeter of chain link fence shall be 3 feet off the face of the top slab of the structure. Posts shall have a maximum spacing of 12 feet on center. The posts shall embed 3 feet into a 10 inch diameter, 3 feet 6 inch deep concrete cylinder with the top of the cylinder crowned 1 inch minimum or 2 inch maximum or according to manufacturer’s requirements, whichever is more stringent.”
  23. Contract Drawing No R-P-GF-64/1512, Sheet 225 of 328:  
Remove the Following: Section 66, Gated Outlet: Remove guardrail.

24. Contract Drawing No R-P-GF-64/1514, Sheet 226 of 328:
- Add the following: "Note 4. Provide a 6-ft tall security chain link fence with one access gate around the perimeter of Discharge Chamber H1. The perimeter of chain link fence shall be 3 feet off the face of the top slab of the structure. Posts shall have a maximum spacing of 12 feet on center. The posts shall embed 3 feet into a 10 inch diameter, 3 feet 6 inch deep concrete cylinder with the top of the cylinder crowned 1 inch minimum or 2 inch maximum or according to manufacturer's requirements, whichever is more stringent."
  - Add the following: "Note 5. Provide a 6-ft tall security chain link fence with one access gate around the perimeter of Gated Outlet H1. The perimeter of chain link fence shall be 3 feet off the face of the top slab of the structure. Posts shall have a maximum spacing of 12 feet on center. The posts shall embed 3 feet into a 10 inch diameter, 3 feet 6 inch deep concrete cylinder with the top of the cylinder crowned 1 inch minimum or 2 inch maximum or according to manufacturer's requirements, whichever is more stringent."
25. Contract Drawing No R-P-GF-64/1543, Sheet 252 of 328:  
Revise the Following: Section 99, Gated Outlet: Remove guardrail.
26. Contract Drawing No R-P-GF-64/1545, Sheet 253 of 328:  
Remove the following: Detail AG: "Remove reference to Detail AD from Detail AG"
27. Remove drawing R-P-GF-64/1551 and replace with amended drawing R-P-GF-64/1551 which is attached to and part of this amendment.

## **B. CHANGES TO SPECIFICATIONS:**

- In Section 01000, General, make the following changes:
  - Paragraph 3.4.4, section h, add the following after the last sentence:  
"Failure to do so will require the contractor to provide traffic control personnel to route agricultural trucks to North 6<sup>th</sup> Street via residential neighborhood to the South. Such personnel could be required around the clock depending on the anticipated haul schedule."
- In Section 01270, Measurement and Payment, make the following changes:
  - Paragraph 1.1.4.1 Add the following after the words excavation in the second sentence. "discharge chamber chain link fence,"
  - Paragraph 1.1.11.1 Add the following after the words excavation in the second sentence. "gated outlet link fence,"
  - Paragraph 1.1.39.1 Add the following after the word concrete in the first sentence. "or bituminous"
  - Paragraph 1.1.40.1 Add the following after the word concrete in the first sentence. "or bituminous"
  - Paragraph 1.1.44.1 Add the following after the word drives in the first sentence. "or roadways"
  - Paragraph 1.1.63., Add the following:  
"1.1.63 Discharge / Gated Outlet Stop Logs  
  
2.1.63.1 Payment  
Payment will be made for costs associated with furnishing materials, fabrication, equipment, and labor and performing all operations necessary for the installation and operation of the stop logs for the gated outlet and discharge chambers. The following equipment shall be included in the lump sum price; six 60-inch panels and three 108-inch panels. This includes, but not limited to, the stop logs panels, seals, and all other accessories. All incidentals shall be included. Stop log guides for each structure will be paid for under either the Phase 2 or Phase 3 Pump station / Gated Outlet Mechanical payment item.  
  
2.1.63.2 Unit of Measure

Unit of Measure: lump sum”

3. Insert Section 02821, Chain Link Fencing and Gates, into Construction Documents, which is attached to and part of this amendment.
4. In Section 02870, Site Furnishings, make the following changes:
  - (a) Paragraph 2.5.7: Add the following after “hunter green” in the first sentence. “and factory primed and painted with a black flat enamel on steel columns.
  - (b) Paragraph 2.5.7, section a: Remove the following “quantity: 2.”
  - (c) Paragraph 2.5.7, section b: Remove the following “quantity: 3”
  - (d) Delete Paragraph 2.5.9, Volleyball Equipment.
5. Remove Specification Section 05615 and replace with amended Specification Section 05615 which is attached to and part of this amendment.

(End of Summary of Changes)